



**SKYE INSTRUMENTS LTD.
21, DDOLE ENTERPRISE PARK,
LLANDRINDOD WELLS,
POWYS. LD1 6DF. U.K.**

TEL: +44 (0) 1597 824811 FAX: +44 (0) 1597 824812
E-Mail: skyemail@skyeinstruments.com

SKH 2053 CONNECTION INSTRUCTIONS

**COLOURS FROM
4 CORE CABLE**

FUNCTION

Red	Positive supply (+12 to +36 volts)
Green	Negative return for Humidity (4-20 mA)
Yellow	Negative return for Temperature (4-20 mA)
Grey	Cable screen
Blue	Not used

SCALING

Humidity	4 mA = 0% RH 20 mA = 100 %RH Linear
Temperature	4 mA = -20 Deg C 20 mA = +70 Deg C Linear